

From  
Sarfaraz Ahmad, I.A.S.,  
Commissioner,  
Greater Warangal Municipal Corporation,  
Warangal.

To  
The Director,  
SCERT, Telangana,  
Hyderabad:

RC. No. HO/DFO/24658/GWMC/COLLEGE/2015, Dt: 16-07-2015.

**Sub:-** Greater Warangal Municipal Corporation – Fire Prevention Wing – Issuance of Renewal of Fire No Objection Certificate for occupancy to the existing Non-MSB of M/s St. Peters College of Teacher Education D.Ed& B.Ed run by St. Peters Educational Association, H.No.2-4-1211, Vidyanagar, T.V. Tower, Hanamkonda - Reg.

**Ref:-** 1. Application of the Correspondent of M/s St. Peters College of Teacher Education D.Ed& B.Ed run by St. Peters Educational Association, H.No.2-4-1211, Vidyanagar, T.V. Tower, Hanamkonda Dt:15-072015.  
2. Rc. No. 5041/B2/97, Dt: 12-03-2010 of the Director General, of State Disaster Response and Fire Services, A.P. Hyderabad.  
3. Inspection report of officers of Fire Prevention Wing, GWMC, Warangal Vide Rc. No. HO/DFO/WMC/24658/2015, Dt:15-07-2015.

\*\*\*

Vide ref. 3<sup>rd</sup> cited, the Officers of the Fire Prevention Wing, GWMC, Warangal have inspected the premises of the M/s St. Peters College of Teacher Education D.Ed& B.Ed run by St. Peters Educational Assosication, H.No.2-4-1211, Vidyanagar, T.V. Tower, Hanamkonda on 15-07-2015.

2.The Management has constructed the Non Multi storied existing School Building with Ground + 2 Upper Floors with a height of 10.00 mtrs for Educational occupancy (B) and submitted application for issuance of Renewal of Fire No Objection Certificate for occupancy to the above existing school building.

**3. Particulars of the Building:**

- a) Address of the Building : M/s St. Peters College of Teacher Education D.Ed& B.Ed run by St. Peters Educational Association, H.No.2-4-1211, Vidyanagar, T.V. Tower, Hanamkonda
- b) Height of the Building : 09.00mtrs
- c) No. of Blocks / Floor : One Block /Ground + 2 Upper Floors
- d) Type of occupancy : Educational (B)
- e) Floor wise details : Given Below

Sl. No.	Floor	Area in Sq. mtrs	Occupancy	Occupants Load
1	Ground Floor	881.00	Educational (B)	250
2	1 <sup>st</sup> Floor	881.00	Educational (B)	150
3	2 <sup>nd</sup> Floor	881.00	Educational (B)	150
	<b>Total:-</b>	2643.00Sq.mtrs		

**4. Means of Escape:-**

The Management has provided 03 No's Internal Stair Cases with a width of 1.50 mtrs, 1.60mtrs and 1.20 mtrs from Ground Floor to Terrace Floor.